

Project:

Order No: Premio EPS80 Compression test

Part No: Premio EPS80/2021_09_16


Customer: Premio Hungária

Tester: Thümler GmbH-Z5

Method: MSZ EN 826

Execution date: 2021. 09. 16. 15:03:35

Chart:



Results:

Nom	Stress [kPa] ,max.	Displacement [mm] ,max.
Premio EPS80/2021_09 _16(1)	81,09	9,99
Premio EPS80/2021_09 _16(2)	87,71	9,99
Premio EPS80/2021_09 _16(3)	88,81	9,99
Premio EPS80/2021_09 _16(4)	89,41	9,99
Max.	89,41	9,99
Min.	81,09	9,99
Mean	86,75	9,99