

Project:

Order No: Premio EPS80 Compression test

Part No: Premio EPS80/2021_10_14


Customer: Premio Hungária

Tester: Thümler GmbH-Z5

Method: MSZ EN 826

Execution date: 2021. 10. 14. 15:09:43

Chart:



Results:

Nom	Stress [kPa] ,max.	Displacement [mm] ,max.
Premio EPS80/2021_10 _14(1)	88,77	9,99
Premio EPS80/2021_10 _14(2)	84,92	9,99
Premio EPS80/2021_10 _14(3)	83,94	9,99
Premio EPS80/2021_10 _14(4)	86,25	9,99
Max.	88,77	9,99
Min.	83,94	9,99
Mean	85,97	9,99