


Project:

Order No: Premio EPS80 Compression test
Part No: Premio EPS80 /2023_03_10
Customer: Premio Hungária

Tester: Thümler GmbH-Z5
Method: MSZ EN 826
Execution date: 2023.03.10. 10:05:40

Chart:



Results:

Nom	Stress [kPa] ,max.	
Premio EPS80 /2023_03_10(4)	87,42	
Premio EPS80 /2023_03_10(6)	84,01	
Premio EPS80 /2023_03_10(7)	81,44	
Max.	87,42	0
Mean	84,29	0