


Project:

Order No: Premio EPS 80 Compression test
Part No: Premio EPS 80 2023_07_25
Customer: Premio Hungária

Tester: Thümler GmbH-Z5
Method: MSZ EN 826
Execution date: 2023.07.25. 13:30:38

Chart:



Results:

Nom	Stress [kPa] ,max.	Displacement [mm] ,max.
Premio EPS 80_2023_07_25	93,78	9,99
Premio EPS 80_2023_07_25	94,57	10,00
Premio EPS 80_2023_07_25	92,71	9,99
<i>Mean</i>	93,69	9,99