


Project:

Order No: Premio EPS 80 Compression test
Part No: Premio EPS 80_2023_09_14
Customer: Premio Hungária

Tester: Thümler GmbH-Z5
Method: MSZ EN 826
Execution date: 2023.09.14.

Chart:



Results:

Nom	Stress [kPa] ,max.	Displacement [mm] ,max.
Premio EPS 80_2023_09_14	87,23	10,00
Premio EPS 80_2023_09_14	87,32	9,99
Premio EPS 80_2023_09_14	90,68	9,99
Premio EPS 80_2023_09_14	90,25	9,99
Premio EPS 80_2023_09_14	88,26	10,00
Mean	88,75	9,99